

1. Manufactured and certified by **York Refrigeration, 100 CV Avenue, Waynesboro, Pennsylvania, 17268-0997, USA**
(Name and address of manufacturer)

2. Manufactured for **THE STELLAR GROUP, 2900 HARTLEY ROAD, JACKSONVILLE, Florida, 32257, USA**
(Name and address of purchaser)

3. Location of Installation **EQUITY GROUP GEORGIA DIVISION LLC, 7220 HIGHWAY 19, CAMILLA, Georgia, 31730, USA**
(Name and address)

4. Type **Horizontal** **150834** **N/A** **547D0725, rev. F** **150834** **2004**
(Horiz. or Vert. tank) (Mfr's serial No.) (CRN) (Drawing No.) (Nat'l. Bd. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 **2001** to **A03**
Code Case Nos. **1518-5, 2053** Special Service per UG-120(d) (year) Addenda (Date)

6. Shell: **SA106B** **3/8** **N/A** **1' 1.25" (ID)** **1' 10.735"**
Mat'l. (Spec. No., Grade) Nom. Thk. (in.) Corr. Allow. (in.) Diam. I.D. (ft. & in.) Length (overall) (ft. & in.)

7. Seams: **S** **None** **85%** **N/A** **N/A** **N/A** **None** **1**
Long. (Welded, Dbl., Sngl., Lap, Butt) R.T. (Spot or Full) Eff. (%) H.T. Temp (°F) Time (hr) Girth. (Welded, Dbl., Sngl., Lap, Butt) R.T. (Spot, Partial or Full) No. of Courses

8. Heads: (a) Mat'l: **SA516-70** (b) Mat'l: **SA516-70**
(Spec. No., Grade) (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	END	1.5	N/A	N/A	N/A	N/A	N/A	N/A	16.5"	N/A
(b)	END	1.375	N/A	N/A	N/A	N/A	N/A	N/A	16.5"	N/A

If removable, bolts used (describe other fastenings) **N/A**
(Mat'l., Spec. No., Gr., Size, No.)

9. MAWP **400/FV** psi at max. temp. **250** °F
Min. design metal temp. **-20** °F at **400/FV** psi Hydro, pneu., or comb. test pressure **Pneu. at 500** psi

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Mat'l.	Nom. Thk.	Reinforcement Mat'l.	How Attached	Location
INLET	1	3	PIPE	SA106B	.216	NONE	UW16.1(c)	
OUTLET	1	3	"	"	"	"	"	
INLET	1	2	"	SA312TP316	.154	"	"	
OUTLET	1	2	"	"	"	"	"	


11. Supports: Skirt **NO** Lugs **N/A** Legs **N/A** Other **N/A** Attached **N/A**
(Yes or no) (No.) (No.) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors, have been furnished for the following items of the report:
N/A
(Name of part, item number, Mfgr's name and identifying stamp)

14" X 22" OIL COOLER ASSY 190 PLATES FOR NON LETHAL/NON CORROSIVE SERVICE IMPACT TEST EXEMPT PER UCS66 (a)


CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. **142** expires **May 28, 2004**

Date **05/03/2004** Co. name **York Refrigeration** Signed  (Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by **York Refrigeration** at **100 CV Avenue, Waynesboro, Pennsylvania, 17268-0997, USA**, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province **MD, DC, VA, DE** and employed by **HSB CT, of Hartford, CT** have inspected the component described in this Manufacturer's Data Report on **April 13, 2004** and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date **05/11/2004** Signed  (Authorized Inspector) Commissions **10966A, MD1065, DC10966, VA901R, DE839** (Nat'l Board (incl. endorsements), State, Prov. and No.)

1. Manufactured and certified by **York Refrigeration, 100 CV Avenue, Waynesboro, Pennsylvania, 17268-0997, USA**
(Name and address of manufacturer)

2. Manufactured for **THE STELLAR GROUP, 2900 HARTLEY ROAD, JACKSONVILLE, Florida, 32257, USA**
(Name and address of purchaser)

3. Location of Installation **EQUITY GROUP GEORGIA DIVISION LLC, 7220 HIGHWAY 19, CAMILLA, Georgia, 31730, USA**
(Name and address)

4. Type **Horizontal** **150839** **N/A** **548E0357, rev. Q** **150839** **2004**
(Horiz. or Vert. tank) (Mfr's serial No.) (CRN) (Drawing No.) (Nat'l. Bd. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 **2001** to **A03**
Code Case Nos. **1518-5, 2053** Special Service per UG-120(d) (year) Addenda (Date)

6. Shell: **SA516-70** **3/8** **NONE** **2' 5.25" (ID)** **12' 6.0"**
Mat'l. (Spec. No., Grade) Nom. Thk. (in.) Corr. Allow. (in.) Diam. I.D.(ft. & in.) Length (overall) (ft. & in.)

7. Seams: **TYPE (1)** **None** **70%** **N/A** **N/A** **TYPE (2)** **None** **1**
Long. (Welded, Dbl., Sngl., Lap, Butt) R.T.(Spot or Full) Eff.(%) H.T. Temp (°F) Time (hr) Girth. (Welded, Dbl., Sngl., Lap, Butt) R.T.(Spot, Partial or Full) No. of Courses

8. Heads: (a) Mat'l: **SA516-70** (b) Mat'l: _____
(Spec. No., Grade) (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a) ENDS	.312	N/A	N/A	N/A	2:1	N/A	N/A	N/A	Concave

If removable, bolts used (describe other fastenings) _____
(Mat'l., Spec. No., Gr., Size, No.)

9. MAWP **300** psi at max. temp. **250** °F

Min. design metal temp. **-20** °F at **300** psi Hydro, pneu., or comb. test pressure **Pneu. at 330** psi.

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Mat'l.	Nom. Thk.	Reinforcement Mat'l.	How Attached	Location
SAFETY	1	1 1/2	CPLG	SA105	3000#	NONE	UW16.2(L)	
LIQ INJ	1	1/2	"	"	"	"	"	
OIL RELIEF OC	1	3/4	"	"	"	"	"	
TEMP ELEM	3	3/4	"	"	"	"	"	
OIL RELIEF	1	1	"	"	"	"	"	

Additional Nozzles - See Attached U-4...

11. Supports: Skirt **NO** Lugs **(4)** Legs **N/A** Other **(16) PADS, SUPPORTS, BRACKETS** Attached **BOTTOM, TOP, SIDES, WELDED**
(Yes or no) (No.) (No.) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors, have been furnished for the following items of the report:
N/A
(Name of part, item number, Mfgr's name and identifying stamp)

30"OD X 169 3/8" HORIZ OIL SEPARATOR FOR NON LETHAL/NON CORROSIVE SERVICE IMPACT TEST EXEMPT PER UCS66 (a)

CERTIFICATE OF SHOP/FIELD COMPLIANCE
We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. **142** expires **May 28, 2004**
Date **05/03/2004** Co. name **York Refrigeration** Signed **[Signature]**
(Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION
Vessel constructed by **York Refrigeration** at **100 CV Avenue, Waynesboro, Pennsylvania, 17268-0997, USA**, I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province **MD, DC, VA, DE** and employed by **HSB CT, of Hartford, CT** have inspected the component described in this Manufacturer's Data Report on **April 13, 2004** and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
Date **05/11/2004** Signed **[Signature]** Commissions **10966A, MD1065, DC10966, VA901R, DE839**
(Authorized Inspector) (Nat'l Board (incl. endorsements), State, Prov. and No.)

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET

As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by York Refrigeration, 100 CV Avenue, Waynesboro, Pennsylvania, 17268-0997, USA
(Name and address of Manufacturer)
2. Manufactured for THE STELLAR GROUP, 2900 HARTLEY ROAD, JACKSONVILLE, Florida, 32257, USA
(Name and address of Purchaser)
3. Location of Installation EQUITY GROUP GEORGIA DIVISION LLC, 7220 HIGHWAY 19, CAMILLA, Georgia, 31730, USA
(Name and address)
4. Type Horizontal N/A 150839
(Horiz, vert., or sphere) (Tank, separator, heat exh., etc.) Mfg's serial No.
- N/A 548E0357, rev. Q 150839 2004
(CRN) (drawing no.) (Nat'l Bd. No.) (Year built)


Additional nozzles, inspection and safety valve openings:


Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Mat'l.	Nom. Thk.	Reinforcement Mat'l.	How Attached	Location
PUMP OUT	1	1	"	"	"	"	"	
MANWAY	1	12X16	FITTING	SA106C	1.0	"	UW16.1(y-2)	Head
OIL CHARGE	1	1	PIPE	SA106B	.179	"	UW16.1(a)	
BLEED	1	1	"	"	"	"	"	
OIL DRAIN	2	1	"	"	"	"	"	
OIL LEV SENSOR	1	1	"	"	.298	"	uw16.1(e)	
HTR CARRIER	2	2	BAR	SA36	.484	"	"	
OIL OUTLET	1	2	PIPE	SA106B	.154	"	"	
SIGHT GLASS	3	2 1/2	"	"	.375	"	"	
OUTLET	1	5	"	"	.258	"	"	
INLET	1	6	"	"	.280	"	"	
INLET	1	6	FLANGE	SA105	300#	"	FIG2.4(3a)	

Additional remarks pertaining to Manufacturer's Partial Data Reports:

Additional Remarks:

Certificate of Authorization: Type "U" No. 142 Expires May 28, 2004

Date 05/03/2004 Name York Refrigeration Signed 
(Manufacturer) (Representative)

Date 05/11/2004 Name  Commission 10966A, MD1065, DC10966, VA901R, DE839
(Authorized Inspector) (Nat'l Board (incl. endorsements), State, Province and No.)